



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

February 21, 2020
Subject: Pavement Milling, HMA
Overlay, with Drainage & Safety
Improvements
State WIN: 023511.00
Location: **Alfred, Arundel, Lyman &
Biddeford**
Amendment No. 1

Dear Sir/Ms.:

Please make the following changes to the Bid Documents:

In the Bid Book:

CHANGE on page 51, CONSTRUCTION NOTES, page 2 of 8, under Shoulder – Right Side, “Station 296+00 To Station 204+00” to read “**Station 296+00 To Station 304+00**”. Make this change in pen and ink.

The following questions have been received:

Question: What are the end treatments on 606.366 3,550 LF remove & reset. What kind of end treatments?


Response: Except for the 8 new 606.1305 31” W-BM GR, MID-WAY SPLICE FLARED TERM and the 50 feet of 606.242 GUARDRAIL TYPE 3D – OVER 15 FT RADIUS, all of the other terminal ends on the 606.366 GUARDRAIL REMOVE AND RESET, TYPE 3C will be removed and reset. The end treatments are FLEAT systems.

Question: Is there a typo in the construction notes on page 51, shoulder spot shim right side station 296+00 to 204+00?

Response: See above changes.

Consider these changes and information prior to submitting your bid on **February 26, 2020**.

Sincerely,


George M. A. Macdougall P.E.
Contracts & Specifications Engineer